

M&E subcontractor to confirm spatial fit of all M&E equipment

76mm Floor build up +waterproofing (3mm) +screed (varies)

1.5 FRONT SECTION THROUGH B-B.

10mm GAP FOR EXISTING CONSTRUCTION TOLERANCES TO BE FILLED WITH USING CEMENT GROUT OR SIMILAR APPROVED. WATERPROOFING SYSTEM TO BOLT HOLES ISSUED BY BM INSTALLED BY RCL.

87mm subject to site survey.

76mm Floor build up +waterproofing (3mm) +screed (varies)

1.5 FRONT ELEVATION A-A.

10mm GAP FOR EXISTING CONSTRUCTION TOLERANCES TO BE FILLED WITH USING CEMENT GROUT OR SIMILAR APPROVED. WATERPROOFING SYSTEM TO BOLT HOLES ISSUED BY BM INSTALLED BY RCL.

802 + 2 (854) FOR GALVANISING MUST BE MAINTAINED

1.5 END SECTION THROUGH BASIN F-F.

10mm GAP FOR EXISTING CONSTRUCTION TOLERANCES TO BE FILLED WITH USING CEMENT GROUT OR SIMILAR APPROVED. WATERPROOFING SYSTEM TO BOLT HOLES ISSUED BY BM INSTALLED BY RCL.

C&P reserve the right to add additional comments to these drawings at a later stage as these drawings were submitted for review, prior to formally agreed C&P design period. As such C&P have not commenced works on the areas related to these drawings and cannot review and comment in full.

Drawer corners to be mitred

1086 O/A DRYWALL TRACKS

1.5 PLAN THROUGH DRAWER SECTION C-C.

1.5 PLAN OF STONE TOP SECTION D-D.

1.5 DETAIL OF INNER ENDS

1.5 DETAIL OF OUTER ENDS

1.5 DETAIL OF CENTRAL DRAWER SUPPORT

DOCUMENT REVIEW

Brookfield MULTIPLEX

BM

BROOKFIELD MULTIPLEX STATUS

A

No Comment

B

Noted subject to comments; correct and resubmit within 5 Business Days

C

Rejected - correct and resubmit within 5 Business Days

BMCE CHECKED BY:

Adrian Dunnett

DATE:

19/07/2016

Incorporate comments and resubmit drawing following release of Level 33/34 survey and architectural 'For Construction' issue drawings.

Sweco-Status B
07-07-2016
K.Shoda

- NOTE: -
- HOLE FOR WASTE FROM WHB THROUGH VANITY UNIT TO BE COORDINATED WITH SEVICE INSTALLATION
 - HOLES FOR HOT & COLD WATER SERVICES REQUIRED. THIS WILL ALSO NEED TO BE COORDINATED WITH OTHER SERVICES AND PENETRATION REQUIREMENT
 - PLEASE REFER TODRG- E1003-81-CPT-XX-127 REV 01 FOR OTHER COMMENTS

READ WITH E1003-81-CPT-XX-130

FOR INFORMATION FOR APPROVAL FOR CONSTRUCTION

DO NOT SCALE

REV DATE BY DESCRIPTION

DIMENSIONS TO BE VERIFIED ON SITE.

FIGURE DIMENSIONS TO BE TAKEN IN PREFERENCE TO THOSE SCALE.

THIS DRAWING IS THE PROPERTY OF JMS SPECIALIST JOINERY LTD.

COPYRIGHT IS RESERVED BY JMS AND THE DRAWING IS LOANED ON THE CONDITION THAT IT IS NOT TO BE REPRODUCED OR COPIED OR IN ANY MANNER WITHOUT THE WRITTEN CONSENT OF JMS.

JMS SPECIALIST JOINERY LTD

UNIT 8, BOURNE END
KINETON ROAD INDUSTRIAL ESTATE
SOUTHAM CV47 0NA
TELEPHONE: 01926 813813
FAX: 01926 812777
E-MAIL: admin@msjoineryltd.co.uk

CLIENT
RAPHAEL CONTRACTING LTD

PROJECT
CENTRE POINT, 103 NEW OXFORD ST.

SCALE
1:10, 1:5 & 1:1.

DRAWN BY
AJG

CHECKED BY

DRAWING TITLE
Apartment type 8, Penthouse Bathroom
Type A, Room 1.3, Vanity Unit Type A,
level 33.

PROJECT No
6538

DRAWING No
E1003-81-CPT-XX-129

DRAWING STATUS
FOR APPROVAL