



M&E subcontractor to confirm spatial fit of M&E equipment

**Status B**  
Submittal was reviewed for design conformity and general conformance with the design intent only within the remit of an architect. The sub-contractor is responsible for confirming and correlating dimensions at job sites for tolerances, clearances, quantities, fabrication processes and techniques of construction, safety, coordination of his work with other trades and full compliance with the contract documents. The review shall not be construed to mean acceptance of the detail design inherent in the drawing, responsibility for which will remain with the sub-contractor. The sub-contractor is responsible for any errors or omissions in the drawing and for meeting all the requirements of the contract documents or otherwise.  
Conran and Partners 06/07/16

C&P reserve the right to add additional comments to these drawings at a later stage as these drawings were submitted for review, prior to formally agreed C&P design period. As such C&P have not commenced works on the areas related to these drawings and cannot review and comment in full.

Sweco -Status B  
07-07-2016  
K.Shoda

NOTE: -  
1. HOLE FOR WASTE FROM WHB THROUGH VANITY  
UNIT TO BE COORDINATED WITH SERVICE INSTALLATION  
2. HOLES FOR HOT & COLD WATER SERVICES REQUIRED.  
THIS  
WILL ALSO NEED TO BE COORDINATED WITH OTHER  
SERVICES  
AND PENETRATION REQUIREMENT  
3. PLEASE REFER TODRG- E1003-81-CPT-XX-127 REV 01 FOR  
OTHER COMMENTS

PF Status B  
13/07/16  
state steel member sizes on drawing

<b>FOR INFORMATION</b>	<b>FOR APPROVAL</b>	<b>FOR CONSTRUCTION</b>	
DO NOT SCALE			
REV	DATE	BY	DESCRIPTION
DIMENSIONS TO BE VERIFIED ON SITE.			
FIGURE DIMENSIONS TO BE TAKEN IN PREFERENCE TO THOSE SCALED.			
THIS DRAWING IS THE PROPERTY OF JMS SPECIALIST JOINERY LTD. COPYRIGHT IS RESERVED BY THEM AND THE DRAWING IS ISSUED ON THE CONDITION THAT IT IS NOT COPIED, REPRODUCED OR OTHERWISE EMPLOYED, IN WHOLLY OR PART UNAUTHORISED PERSONS EITHER WHOLLY OR IN PART WITHOUT THE CONSENT IN WRITING OF:			
 <b>JMS SPECIALIST JOINERY LTD</b>			
UNIT 6,BOURNE END KINETON ROAD INDUSTRIAL ESTATE SCOTTHAM CV47 0NA <b>TELEPHONE:01926 813813</b> <b>FAX:01926 812777</b> <b>E-MAIL: admin@jmsjoineryltd.co.uk</b>			
CLIENT <b>RAPHAEL CONTRACTING LTD</b>			
PROJECT <b>CENTRE POINT, I O3 NEW OXFORD ST.</b>			
SCALE <b>I=5</b>		DATE <b>21-11-2015</b>	
DRAWN BY <b>AJG</b>		CHECKED BY	
DRAWING TITLE <b>Apartment type 6,Penthouse Bathroom Type G,Room 9,Vanity Unit, Type A, level 34.</b>			
PROJECT No <b>653X</b>		REVISION	
DRAWING NO <b>E1003-B1-CPT-XX-I 39</b>		<b>-</b>	
DRAWING STATUS <b>FOR APPROVAL</b>			