Status B
Submittal was reviewed for design conformity and general conformance with the design intent only within the remit of an architect. The sub-contractor is responsible for confirming and correlating dimensions at job sites for tolerances, clearances, quantities, fabrication processes and techniques of construction, safety, coordination of his work with other trades and full compliance with the contract documents. The review shall not be construed to mean acceptance of the detail design inherent in the drawing, responsibility for which will remain with the sub-contractor. The sub-contractor is responsible for any errors or omissions in the drawing and for meeting all the requirements of the contract documents or otherwise.
Conran and Partners 06/07/16

C&P reserve the right to add additional comments to these drawings at a later stage as these drawings were submitted for review, prior to formally agreed C&P design period. As such C&P have not commenced works on the areas related to these drawings and cannot review and comment in full.

2056 TRACK FACES

M&E subcontractor to confirm spatial fit of all M&E equipment



1.5 FRONT SECTION THROUGH B-B.

10mm GAP FOR EXISTING CONSTRUCTION TOLERANCES TO BE FILLED WITH USING CEMENT GROUT OR SIMILAR APPROVED. WATERPROOFING SYSTEM TO BOLT HOLES ISSUED BY BM INSTALLED BY RCL.



1.5 FRONT ELEVATION. A-A

10mm GAP FOR EXISTING CONSTRUCTION TOLERANCES TO BE FILLED WITH USING CEMENT GROUT OR SIMILAR APPROVED. WATERPROOFING SYSTEM TO BOLT HOLES ISSUED BY BM INSTALLED BY RCL.

10mm GAP FOR EXISTING CONSTRUCTION TOLERANCES TO BE FILLED WITH USING CEMENT GROUT OR SIMILAR APPROVED. WATERPROOFING SYSTEM TO BOLT HOLES ISSUED BY BM INSTALLED BY RCL.

Drawer to be half depth

Sweco status B
07-07-2016
K.Shoda

NOTE: -
1. HOLE FOR WASTE FROM WHB THROUGH VANITY UNIIT TO BE COORDINATED WITH SEVICE INSTALLATION
2. HOLES FOR HOT & COLD WATER SERVICES REQUIRED. THIS WILL ALSO NEED TO BE COORDINATED WITH OTHER SERVICES AND PENETRATION REQUIREMENT
3. PLEASE REFER TODRG- E1003-81-CPT-XX-127 REV 01 FOR OTHER COMMENTS

Drawer to be half depth- Rear compartment to be removed

2056 O/A DRYWALL TRACKS

1.5 PLAN THROUGH DRAWER SECTION C-C.

593 + 12mm TBC

1.5 PLAN OF STONE TOP SECTION D-D.

READ WITH E1003-81-CPT-XX-139 & 140

FOR INFORMATION	FOR APPROVAL	FOR CONSTRUCTION

DO NOT SCALE

REV	DATE	BY	DESCRIPTION

DIMENSIONS TO BE VERIFIED ON SITE.

FIGURE DIMENSIONS TO BE TAKEN IN PREFERENCE TO THOSE SCALE

THIS DRAWING IS THE PROPERTY OF JMS SPECIALIST JOINERY LTD.

COPYRIGHT IS RESERVED BY THEM AND THE DRAWING IS ISSUED ON THE CONDITION THAT IT IS NOT COPIED/REPRODUCED/RETAINED/ OR DISCLOSED TO UNAUTHORISED PERSONS EITHER WHOLLY OR IN PART WITHOUT THE CONSENT IN WRITING OF :

JMS SPECIALIST JOINERY LTD
UNIT B,BOURNE END
KINETON ROAD INDUSTRIAL ESTATE
SOUTHAM CV47 0NA
TELEPHONE:01926 813813
FAX:01926 812777
E-MAIL: admin@jmsjoineryltd.co.uk

CLIENT	RAPHAEL CONTRACTING LTD
PROJECT	CENTRE POINT,103 NEW OXFORD ST.
SCALE	1-10,1-5 & 1-1.
DATE	21-11-2015
DRAWN BY	AJG
CHECKED BY	
DRAWING TITLE	Apartment type B,Penthouse Bathroom Type G,Room 9.Vanity Unit Type A, level 34.
PROJECT No	6538
REVISION	-
DRAWING No	E1003-81-CPT-XX-138
DRAWING STATUS	FOR APPROVAL

DOCUMENT REVIEW Brookfield MULTIPLEX BM

BROOKFIELD MULTIPLEX STATUS
A No Comment
(B) Noted subject to comments; correct and resubmit within 5 Business Days
C Rejected – correct and resubmit within 5 Business Days

BMCE CHECKED BY: Adrian Dunnett
DATE: 19/07/2016

Incorporate comments and resubmit drawing following release of Level 33/34 survey and architectural 'For Construction' issue drawings.



1.5 PLAN OF SUB TOP.



1.5 UNDERSIDE VIEW OF POTBOARD MACHINING.



1.5 APRON DETAIL.