

Electricity Tx Projects Only

Capital Delivery Construction National Grid

Issue: Rev 3 (Dec 2015)

ITEMS REQUIRING A TASK SPECIFIC RISK ASSESSMENT THESE ITEMS CAN ONLY BE USED IF NO SAFER ALTERNATIVE SOLUTION IS AVAILABLE

Steel fence pins



1 Tonne mini dumper



Mini excavator



Cherry Picker type MEWP



Scissor lift type MEWP



Metal road plates



Metal ladders in Substations



Metal tape measures in Substations or on OHL projects



Disc cutters



All craft type knives



Wellington boots



Non PPE clothing directly under helmets



Previous incorrect use and management of the above items has been identified as a root cause of several accidents and incidents on National Grid projects. As a result, the Capital Delivery Construction Senior Management team has identified that additional control measures must be detailed in a Task Specific Risk Assessment prior to use.